DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/18/2015 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01		(X3) DATE SURVEY COMPLETED		
		155162	B. WING _	B. WING		R 02/13/2015	
NAME OF PROVIDER OR SUPPLIER				ST	REET ADDRESS, CITY, STATE, ZIP CODE	1 02/	13/2013
AUTUMN DIDGE DELIABILITATION GENTDE				60	600 WASHINGTON AVE		
AUTUMN RIDGE REHABILITATION CENTRE				WABASH, IN 46992			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFI) TAG	x	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS		{K 0	00}			
	A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 11/26/14 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 02/13/15 Facility Number: 000081 Provider Number: 155162 AlM Number: 100289570 Surveyor: Amy Kelley, Life Safety Code Specialist; Thomas Forbes, Life Safety Code Specialist At this PSR survey, Autumn Ridge Rehabilitation Centre was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This three story facility was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and resident rooms 301 to 306 and 324 to 326. The facility has a capacity of 100 and had a census of 59 at the time of this survey. Quality Review by Dennis Austill, Life Safety Code Specialist on 02/17/15.						
					TITLE		(YE) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

LE (X6) DAT

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.